



Notes:

1. 1.5 x 1.5 x 1.39 m Pull pit as shown.
2. Concrete designed for AASHTO HS20 live load.
3. Unit c/w 0.56 x 0.56 m square k/o core as shown.
4. Unit c/w 4-cable channels as shown.
5. Unit supplied w/ lifting insert as required.
6. Unit c/w threaded inserts if required.
7. Chamber to have 0.165 x 0.165 x 0.125 m deep sump as shown.
8. Approximate mass:
  - Lid: 1,000 kg.
  - Chamber: 2,250 kg.
9. Minimum rebar yield strength: 414 MPa.
10. Minimum concrete strength: 35 MPa.
11. All dimensions are in millimeters.



The LANGLEY CONCRETE Group of Companies

DESCRIPTION: Vault 1.5 x 1.5  
w/ Galvanized Steel Hatch  
Occasional Traffic Only  
[www.langleyconcretegroup.com](http://www.langleyconcretegroup.com)

DRAWN BY:	KS	ORIGIN:	CHWK
CHK BY:	SW	DWG NO:	V1.5x1.5-1.0
DATE:	FEB/01/2010	REV DATE:	2. MAY/06/2010
SCALE:	1:30		

This drawing is the property of the Langley Concrete Group of Companies. All information contained herein is confidential and may not be used in whole or in part without written permission from the owner.